



WINNIPEG SCHOOL DIVISION

Building Department

1395 Spruce Street, Winnipeg, Manitoba R3E 2V8

Telephone: (204) 775-1392

Fax: (204) 774-6406

ADDENDUM NO. 2

Project No. 85665, 85666, 85667

Dated October 26, 2009

ELECTRICAL SERVICE UPGRADE PHASE 8

at

VARIOUS SCHOOLS
(Brock Corydon, Rockwood, Shaughnessy Park)

This addendum shall be incorporated with the specifications and shall form part of the contract documents. Please note the changes, corrections, information and/or instructions in connection with the work to be done under this contract.

The purpose of this addendum is to clarify the following:

1. Refer to Electrical Specification

.1 2.12.18 Arc Flash Ratings

The Arc Flash ratings referenced in specification refers to the manufacturers' warning labels only as required by City of Winnipeg Electrical By-law.

M.R.